

**FIRE INSPECTOR'S
INTER-OFFICE CORRESPONDENCE**

TO: Genaro Argenio, Planning Board Chairman

FROM: Kenneth Schermerhorn, Asst. Fire Inspector (KS)

SUBJECT: PB-08-01
Legacy Woods (Knox Village)
SBL: 70-1-49.2

DATE: January 16, 2008

Fire Prevention Reference Number: FPS-08-001

A review of the above referenced plan has been conducted and is disapproved for the following reasons:

- 1) Request additional hydrants at North East corner of Buildings 1 & 5

Note A: Drawing G4 shows something at South East corner of building # 1 which I believe to be a hydrant also.

Note B: Depending on locations of Fire department connections for Buildings (not supplied) hydrant locations may be changed.

Note C: Fire Lanes to be 30 feet as per Town code, note on G2 states this but drawings scale does not coincide with note.

1/16/08
cc: M.E.
D.C.
Appl.